

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-link, NH-System

Name and address of the applicant

ETI Elektroelement d.o.o.
Obrezija 5, 1411 IZLAKE
SLOVENIA

Name and address of the manufacturer

ETI Elektroelement d.o.o.
Obrezija 5, 1411 IZLAKE
SLOVENIA

Name and address of the factory

ETI Elektroelement d.o.o.
Obrezija 5, 1411 IZLAKE
SLOVENIA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Rated voltage: 690 V a.c.
Additional information see page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NH 2C; NH 2CI, NH 2; NH 2I

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-1:2006/AMD2:2014
IEC 60269-2:2013
IEC 60269-2:2013/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

240417-TL3-1; 240417-TL3-2

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-02-26

Signature:

A. Fabian

Additional information (if necessary)

Rating and principal characteristics:

Rated current: 63 A - 315 A

Breaking capacity: 120 kA

Characteristic: gG

Size: NH 2

Dimensions: compact size (NH 2CI, NH 2C); normal size (NH 2I, NH 2)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-02-26

Signature:



A. Fabian